



# CERTIFICATE OF CONFORMITY

This is to certify that

**DuPont™**

**Tyvek® Breathable Self-Supporting Fire Retardant  
Synthetic Roof Underlays**



**Complies with the New Zealand Building Code:**

1. B2.3.1 (a) and B2.3.2 (b).
2. C3.4(c).
3. E2.3.2.
4. F2.3.1.

## Product Description

DuPont™ Tyvek® Breathable Self-Supporting Fire Retardant Synthetic Roof Underlays are synthetic building underlays for use under roof claddings.

Trade Names:  
DuPont™ Tyvek® Supro (2506B)  
DuPont™ Tyvek® Supro Plus (2506B)  
DuPont™ Tyvek® Pro (2508B)

The underlays are spun bonded high density polyethylene, laminated to a non-woven polypropylene sheet. The product is coloured grey on the top face and white on the bottom face.

## Certificate Holder

**DuPont™ Australia Ltd.**

ABN: 59 000 716 469  
Level 3, 7 Eden Park Drive  
Macquarie Park, NSW  
Australia 2113  
Ph: 02 9923 6148  
W: www.dupont.com



## Certification Body

**CertMark International Pty Ltd**

ABN: 80 111 217 568  
JAS-ANZ Accreditation No. Z4450210AK  
PO Box 321 Tuakau 2121  
+64 (09) 951 8246  
www.CertMark.org

## Product Purpose or Use

For use under roof claddings on timber-framed and steel-framed buildings to limit wind entry and assist with moisture management.

## Subject to the following Conditions & Limitations:

- a. To meet the durability requirements of the NZBC, DuPont™ Tyvek® Supro (2506B), Tyvek® Supro (2506B) Plus & Tyvek® Pro (2508B) roof underlays must only be installed in roofs with a pitch of 3° or more and in accordance with the 'DuPont™ Tyvek® Supro / Supro Plus / Pro Installation Guide – New Zealand', Version 28-Feb-17.
- b. Must be separated from fireplaces, heating appliances, flues and chimneys in accordance with the requirements of NZBC Acceptable Solutions C/AS1 to C/AS6, Paragraph 7.5.9 for the protection of combustible materials.
- c. The certificate holder must maintain compliance with the conditions set out in Section 15 of the Building (Product Certification) Regulations 2008.
- d. This certificate is limited to the details within this certificate, including the compliance elements, product description and purpose or use. This certification is to be read, considered and used as a whole document and reproduced in its entirety.

  
**John Thorpe**  
CertMark International Pty Ltd

09/06/2015  
**Date of Issue**

CMA-CM40146-I01-R03  
**Certificate Number**  
Revised April 2017

- This certificate is issued by an independent certification body accredited by the product certification accreditation body appointed by the Chief Executive of the Ministry of Business, Innovation & Employment (MBIE) under the Building Act 2004. MBIE does not in any way warrant, guarantee, or represent that the building method or product the subject of this certificate conforms to the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. MBIE disclaims, to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages, and costs arising as a result of the use of the building method(s) or product(s) referred to in this certificate
- It is advised to check that this Certificate of Conformity is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the MBIE website, www.mbie.govt.nz
- This certificate may only be reproduced in its entirety.

